

ADDENDUM No. 2
TO THE
SPECIFICATIONS OF LABOR AND MATERIAL
IN CONNECTION WITH
CONSTRUCTION OF A
MARDI GRAS PAVILION AND PARK
MOBILE, ALABAMA
FOR THE CITY OF MOBILE, ALABAMA
PROJECT No. MG-070-15

AUGUST 28, 2015

Prepared by:

HOLMES & HOLMES ARCHITECTS
P.O. BOX 864
MOBILE, ALABAMA 36601
OFFICE (251) 432-8871
FAX (251) 433-7096

ITEMS:

- ITEM 1. Bid Date
 - ITEM 2. Contractor's License
 - ITEM 3. Approved Equal
 - ITEM 4. Lettering
 - ITEM 5. RFI
- ATTACHMENT(S)

ITEM 1. Bid Date

- A. The bid date has been set back two (2) weeks, to September 16, 2015, same time, same place. A second pre-bid meeting will be held at 2:00 p.m. September 3, 2015 at the same place (AE conference room). This applies to all parties including those that attended the previous pre-bid meeting.

ITEM 2. Contractor's License

- A. If the base bid is accepted the contractor must have the State License Type MU. If the Alternate is accepted the Contractor must have State License Type BC, provided that the difference in the alternate exceeds the base bid.

ITEM 3. Approved Equal

- A. Commercial Door Systems CDS F200 FRP is approved equal to the Special Lite "SL-17" provided all components meet or exceed the specifications.
- B. Roof Sheet: MRD194/Dutch Seam by Atas International Inc. is approved as an equal to the roof sheet specified provided all components meet or exceed the specifications.

ITEM 4. Lettering

- A. See specifications page 10A-2 Lettering. Amplify this paragraph as follows:
"The contractor shall furnish the letters as written on Section A/A-8 with the date to be completed later. The letters shall be eight (8) inches high of bronze anodized aluminum. The letters shall be constructed by ARK Ramos using the ARK Ramos "Classic." Furnish shop drawings for Architect's approval complete with details of attachment."

ITEM 5. RFI

Question: "Details on the precast inlets-primarily the grate inlet casting
Pipe size and type connecting to CI#5 & JB#8
Can 18" x 11" or 15" rcp be substituted for the 12" rcp?
Please advise."

Answer: The pipe needs to remain as a 12" diameter RCP.

ATTACHMENT(S):

- None.