



ADDENDUM

February 13, 2020

RE: City of Mobile Bid #5383 for Generator

Please consider the following to be Addendum to City of Mobile Bid # 5383 for Generator

Generator #3:

DELETE:

Generator 150 KW 408- Volt 3 Phase 60 Hz Diesel Engine

REPLACE WITH:

Generator 150 KW 277/480 volt 3 phase 60 Hz Diesel Engine

Generator #4:

DELETE:

Generator 150KW 208/120 volt 3 Phase Diesel Engine as per the following and attached.

REPLACE WITH:

Generator 150KW 120/208 volt 3 phase Diesel Engine

DELETE:

Generator shall be a used, reconditioned or refurbished generator is not being requested will be rejected.

REPLACE WITH:

Generators shall be NEW. USED, RECONDITIONED, or REFURBISHED Generators are NOT BEING REQUESTED and will be rejected.

Thank you for your consideration in this matter.

Sincerely

A handwritten signature in blue ink, appearing to read 'John Paine', is written over the word 'Sincerely'.

John Paine
Purchasing Agent
JP/ TAJB