

ADDENDUM #2

July 20, 2023



RE: City of Mobile Bid #5821 for Oil and Grease Room Upgrades

Please consider the following to be ADDENDUM #2 to City of Mobile Bid #5821 for Oil and Grease Room Upgrades.

ADD

Oil and water separator systems to be replaced on all oil type delivery systems.

ADD

Solenoid valves to be replaced.

ADD

Both ceiling-mounted grease reels are to be replaced. Hoses shall reach all corners of the grease room.

ADD

Remove 90WT oil tank and dispensing system.

Replace with new 400-gallon double-walled tank and dispensing system to include new pump and reel with hose.

ADD

Remove existing hose reels for grease and hydraulic oil/fluid of building with new hose reels with hoses.

Hose length to be 100 feet.

ADD

Used oil tank is not to be disturbed or replaced.

Thank you for your consideration in this matter.

A handwritten signature in blue ink, appearing to read 'John Paine', is written over the typed name and title.

John Paine
Purchasing Agent
City of Mobile
JP/en