



Addendum No. 1

To: Pre-Bid Meeting Attendees and Registered Plan holders

From: Gregg Blaize
City of Mobile Architectural Engineering Department

Re: Arthur R. Outlaw Convention Center- Exhibit Hall Operable Wall
Wallcovering Replacement
Project # CNN-022-23

Date: January 6, 2023

This Addendum forms a part of, and modifies, the Project Manual for the above referenced project, dated December 6, 2023. Acknowledge the receipt of this Addendum No. 1 and all subsequent Addenda, if any, in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

General:

Item 1. The Pre-Bid Meeting Agenda **with Modifications** and Pre-Bid Meeting Acknowledgment Roster, dated December 28, 2022 are attached and form part of Addendum No. 1. Revisions to the Pre-Quote Agenda are indicated with a strike-through for deletions and **bold italic** typeface for additions.

Forms and Specifications:

Item 1. The Scope of Work has been modified to include all labor, materials, tools and equipment necessary to safely strip existing wall coverings from four (4) 29'6" x 21" wide wall panels and install Rib Fabric on each of the four (4) wall panels. The New Summary of Work is as follows:

Furnish 1080 yards of Hytex – Rib Fabric (Color: Azure) and provide all labor, materials, tools and equipment necessary to safely strip existing wall coverings from ninety- eight (98) panel faces and install new fabric over ninety-eight (98), 29'-6" operable panel faces and **four (4) 29'6" x 21" wide wall panels.**

Item 2. Hytex Rib Navy (Product #19-27) has been approved as a substitute fabric.

Drawings: N/A

RFI's:

Item 1. Question: Do you know what the material of these operable panels are?

Answer: Welded Steel

Item 2. Question: Will there be a safe place to store 1-2 Scissors Lift during Install?

Answer: Yes. Storage of lifts and materials will be predicated on Event Calendar and Contractor may be required to move lifts and materials to various locations throughout the install process.

END OF ADDENDUM NO. 1