



Addendum No. 3

To: Pre-Quote Meeting Attendees and Registered Plan holders

From: David M. Cordingly
City of Mobile Architectural Engineering Department

Re: MFRD Boat Lift & Dock Improvements
Project #FD-040-23

Date: July 18, 2023

This Addendum forms a part of, and modifies, the Request for Quotes for the above referenced project. Acknowledge the receipt of this Addendum No. 3 and all subsequent Addenda, if any, in the space provided on the Quote Form. Failure to do so may subject Contractor to disqualification.

Clarifications:

- A. **Bid Date/Time:** Please note that the Bid Date has been revised. Bids will now be received until **Wednesday, July 26, 2023 until 2:00 PM local time** in the Office of the City Clerk, 9th Floor South Tower, Government Plaza, 205 Government Street, Mobile, Alabama 36602. The same will be publicly opened and read at 2:30 PM local time in the Atrium Lobby of Government Plaza.
- B. **Base Bid:**
Additional electrical scope: In addition to the original Base Bid Scope of Work for the boat lift and dock improvements, Contractor is to furnish all labor, materials, tools, supplies, and equipment necessary to properly install two (2) 30-Amp RV style Power Outlet Boxes for shore power. Boxes are to be enclosed, lockable, and weatherproof. Contractor is to coordinate final locations with Owner.
- C. **Alternate No. 1:**
Additional electrical scope: In addition to the original Alternate No. 1 Scope of Work for the boathouse, Contractor is to furnish all labor, materials, tools, supplies, and equipment necessary to properly install four (4) exterior grade LED light fixtures flush mounted to the underside of the boathouse, and an exterior grade light switch. Fixtures need to adequately light the underside of the boathouse, which will be located approximately 18-20 feet above the walkway. Contractor is to coordinate final light switch location with Owner.

Drawings: N/A

RFI's: N/A

Attachments: N/A

END OF ADDENDUM NO. 3