



Addendum No. 2

To: City of Mobile bidding website

From: Jody Russell
City of Mobile Architectural Engineering Department

Re: Ben May Library – Chiller Replacement
Project #LI-034-23

Date: March 20, 2024

This Addendum forms a part of, and modifies, the Bidding Documents for the above referenced project, dated February 28, 2024. Acknowledge the receipt of this Addendum No. 2 and all subsequent Addenda, if any, in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

General: N/A

Clarifications: N/A

Forms and Specifications:

N/A

Drawings: N/A

RFI's: 1. Will a shutdown from Friday morning – Sunday night be acceptable?

A shutdown of the library for installment is acceptable from Friday morning until Sunday afternoon (60 hours) with a Seven (7) day prior notification to allow the library time to prepare for closure. Low bidder shall advise which weekend they prefer. More than likely it will be acceptable; however, must confirm the date with the library.

2. Will temporary cooling be required for the duration of the shutdown since the building will be closed to occupants?

Yes. Normal temperature and humidity levels must be maintained by the contractor due to the books in the library. (temperature range 70-74*, humidity 55%-65%)*

ATTACHMENTS

N/A

END OF ADDENDUM NO. 2