

ADDENDUM NUMBER THREE
200 Government Third Floor Renovations
City of Mobile Project Number MX-068-22

Date: January 25, 2023

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents as noted below. Direct any questions, comments or discrepancies to Steve Stone at steve@dakinsteet.com.

PART 1 - GENERAL CHANGES (N/A)

PART 2 - CHANGES TO THE FORMS AND CONDITIONS (N/A)

PART 3 - CHANGES TO THE SPECIFICATIONS (N/A)

PART 4 - CHANGES TO THE DRAWINGS

4.01 In lieu of the specified 2x4 wood studs @ 16" O.C. , 3 5/8" x 25ga Metal Studs @ 16" O.C. may be used.

PART 5 – ATTACHMENTS (N/A)

END OF ADDENDUM