



Addendum No. 2

To: Pre-Bid Meeting Attendees and Registered Plan holders

From: Elizabeth Miller
City of Mobile Architectural Engineering Department

Re: CIP D7 Senior Center
Project # PR-049-25

Date: August 19, 2025

This Addendum forms a part of, and modifies, the Request for Bids for the above referenced project, dated August 13, 2025. Acknowledge the receipt of this Addendum No. 2 and all subsequent Addenda, if any, in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

General: N/A

Clarifications:

Item 1. The existing interior panels are to be completely removed.

Item 2. Use existing conduit where feasible (i.e. concealed in walls) - all surface mounted conduit (new and existing) is to be painted to match surface on which it is installed. Box covers are to be labeled on the interior of cover.

Forms and Specifications: N/A

Drawings: N/A

RFI's:

Question 1. In order to finalize a proposal for Builder's Risk insurance required by the Contract we will need the following information:

1. Year Built
2. Type of Roof
3. Approximate Monetary value of the building

Answer 1. Below is the requested information for the Builder's Risk insurance

1. Building was built in 1958
2. It has a built-up roof (BUR).
3. The approximate value is \$375,000.

END OF ADDENDUM NO. 2