

PURCHASING DEPARTMENT

ADDENDUM

April 26, 2019



RE: City of Mobile Bid #5278 for:

NEW PORTABLE 25 TON AIR CONDITIONING/HEATING UNIT

Gentlemen:

Please consider this to be an Addendum to City of Mobile Bid #5278 for New Portable 25 Ton Air Conditioning/Heating Unit

Additional Information:

- Unit is Air Cooled – No Water
- Must have a minimum of two (2) outlets and two (2) inlets
- To use 480 Volt
- Cable to have Terminal Block Power Connection
- Unit will be used to Cool/Heat Large Tent
- Must be on skid type platform so unit can be moved by a Forklift
- City will remove from rear of truck
- Unit to be set at rear of truck for removal by City of Mobile
- Vendor/Shipper shall Notify the City of Planned Delivery, no less than forty eight (48) hours prior to an intended delivery
- If Vendor/Shipper fails to notify the City no less than forty eight (48) hours, prior to the attempted delivery
- City will not pay re-delivery charges or waiting fees if City is not notified, no less than forty eight (48) hours
- City may change delivery location prior to the delivery
- Freight to be included in price of unit
- Quote delivered prior FOB Mobile, Ala
- Quote Heating capacity equal to 25 ton cooling
- City will consider options, within the above and previously stated terms on the Bid Form

Thank you for your consideration in this matter.

Sincerely,

A handwritten signature in blue ink, appearing to read 'John Paine', is written over a horizontal line.

John Paine
City of Mobile
Purchasing Agent