



MOBILE FIRE - RESCUE DEPARTMENT FIRE CODE ADMINISTRATION

Child Care Inspection - Residential

Facility Name: _____ Occupancy Number: _____

Facility Address: _____

Responsible Person: _____

- _____ Maximum amount of Children allowed is **5** (IFC Section 202)
- _____ Address is visible
- _____ Care shall be provided within the home, not a separate building
- _____ Emergency plan readily available including emergency contacts
- _____ Emergency lighting (readily accessible flashlight)
- _____ Smoke detectors properly operating in sleeping areas
- _____ Type, number of exits acceptable
- _____ Exit doors and windows easily open from the inside
- _____ Access to exits is clear of obstruction
- _____ Interior finish acceptable
- _____ Heat source(s) properly protected
- _____ Proper use of electrical equipment and multi plug adaptors
- _____ Outlet covers on unused receptacles
- _____ Combustible Storage acceptable
- _____ Fire extinguisher accessible (min. 2A10BC) – properly tagged
- _____ Class K fire extinguisher accessible in the kitchen area – properly tagged
- _____ General Over-All Housekeeping is acceptable

Comments: _____

This office is concerned with identifying conditions that promote a safe environment free of fire hazards including but not limited to the above key concepts from the 2012 International Fire Code and DHR.

Date of Inspection ____/____/____ _____

Fire Code Administration Staff