



MOBILE FIRE - RESCUE DEPARTMENT

FIRE CODE ADMINISTRATION

Fire Code Compliance Inspection

Cooking Concession Operations

A Fire and Life Safety Inspection of cooking concessions is required from the Fire Code Administration prior to operations at public events or locations within the City of Mobile.

An exhaust hood vent and fire suppression system, a portable fire extinguisher (in addition to the “K” extinguisher) shall be provided with a minimum rating not less than 2A:10BC and an approved way out of the concession area shall be maintained in a safe condition and shall be available for immediate use and free of all obstructions at all times.

Name of Public Assembly Event or Location:

Location of Concession:

Concessionaire's Name:

Concessionaire's Name (if applicable):

Fire Suppression System Contractor:

Concessionaire's Address:

Requirements include but may not be limited to the following:

	Hood suppression system		Certified within 6 months and free of grease
	Pull ring		Near exit and easily accessible
	“K” extinguisher		Easily accessible and within date
	2A 10BC extinguisher		Easily accessible and within date
	Housekeeping		Area free of trash and garbage
	Exit(s)		Clear path of egress

Comments: _____

Acceptance Inspection ____/____/20____ Fire Code Official _____