Date of Inspection / /



MOBILE FIRE - RESCUE DEPARTMENT FIRE CODE ADMINISTRATION Fire Safety Consultation-Residential Care Facility

Facility Name:_____Occupancy Number: _____

By signature I attest, the number of occupants receiving carewhich are not related by blood are marrige is equal to or less than 5. Signed: _____ Print Name: _____

		No	Comment
	Address is visible		
	Care shall be provided within the home, not a separate building		
	Emergency plan readily available including emergency contacts		
	Emergency lighting (readily accessible flashlight)		
	Smoke detectors properly operating in sleeping areas		
	Type, number of exits acceptable		
	Exit doors and windows easily open from the inside		
	Access to exits is clear of obstruction		
	Interior finish acceptable		
	Heat source(s) properly protected		
	Proper use of electrical equipment and multi plug adaptors		
	Outlet covers on unused receptacles		
	Combustible Storage acceptable		
	Fire extinguisher accessible (min. 2A10BC) – properly tagged		
	Class K fire extinguisher accessible in the kitchen area – properly tagged		
	General Over-All Housekeeping is acceptable		
Comme	nte.		
Comme	nts:	on Fee:	\$61.00
Comme	Re-inspection/Consultation	on Fee: Other:	\$61.00
Comme	Re-inspection/Consultation	Other:	\$61.00

limited to the above key concepts from the 2018 International Fire Code. While this document offers recommendations for a residence used as a daycare, actual enforcement of any codes, regulations, rules, etc with 5 or LESS persons who are not related by blood or marriage, is not under the scope of this office.