



# MOBILE FIRE - RESCUE DEPARTMENT FIRE CODE ADMINISTRATION

## Adult Care Facility Checklist

- \_\_\_\_ Address is visible from street.
- \_\_\_\_ Fire drills documented.
- \_\_\_\_ Fire safety and evacuation plans current.
- \_\_\_\_ Exit doors open with little effort and have proper hardware.
- \_\_\_\_ Exits are clear of obstruction.
- \_\_\_\_ Emergency lighting is operational.
- \_\_\_\_ Smoke detectors are operational and have current inspections.
- \_\_\_\_ Fire alarm is in compliance and has a current inspection.
- \_\_\_\_ Sprinkler is in compliance and has current inspection.
- \_\_\_\_ 2A/10 BC extinguisher is in compliance and has current inspection.
- \_\_\_\_ Hood suppression is installed over cooking appliances.
- \_\_\_\_ Hood suppression is in compliance and has current inspection.
- \_\_\_\_ Class K fire extinguisher is in compliance and has current inspection.
- \_\_\_\_ Proper use of electrical equipment and multi plug adaptors.
- \_\_\_\_ Combustible storage is stacked 2' below the ceiling height.

This office is concerned with identifying conditions that promote a safe environment free of fire hazards including but not limited to the above key concepts from the 2021 International Fire Code and DHR. This document is meant for guidance in preparation of a requested Fire Code Inspection, it is not meant to limit the Fire Code Officials Inspection.