



MOBILE FIRE - RESCUE DEPARTMENT FIRE CODE ADMINISTRATION

Child Care Commercial Checklist

- ___ Address is visible from the street.
- ___ Fire drills are documented.
- ___ Fire safety and evacuation plans are in compliance.
- ___ Exit doors open with little effort and have proper hardware.
- ___ Exits are clear of obstructions.
- ___ Emergency lighting is operational.
- ___ Fire alarm is in compliance and has a current inspection.
- ___ Sprinkler is in compliance and has a current inspection.
- ___ 2A/10 BC extinguisher is in compliance and has a current inspection.
- ___ Hood suppression is installed over cooking appliances.
- ___ Hood suppression is in compliance and has a current inspection.
- ___ Class K fire extinguisher is in compliance and has a current inspection.
- ___ Less than 20% of walls covered in decorative materials.
- ___ Heat source(s) are properly protected.
- ___ Proper use of electrical equipment and multi plug adaptors.
- ___ Outlet covers are on unused receptacles.
- ___ Combustible Storage is stacked 2' below the ceiling height.

This office is concerned with identifying conditions that promote a safe environment free of fire hazards including but not limited to the above key concepts from the 2021 International Fire Code and DHR. This document is meant for guidance in preparation of a requested Fire Code Inspection, it is not meant to limit the Fire Code Officials Inspection.