

Contractor Permit Submission Requirement Checklist

Fire Hydrant and Underground Water Supply

1. Location including street address and occupant business name.
2. Provide site plan to scale showing the location of hydrants, piping, and thrust blocks.
3. Thrust blocks are required for backflow preventer installed per MAWSS.
4. Provide data sheets on all materials including type of pipe, fittings and appurtenances of the installation.
5. Indicate hydrant connections direction on the site plan.
6. Indicate the hydrant bonnet color per the water flow.

Blue (1500 GPM or >) Green (1000-1500 GPM) Orange (500-1000 GPM) Red (<500 GPM)