



CURB & GUTTER DETAIL

NOT TO SCALE

## NOTES:

SIDEWALK PANELS THAT ABUT THE DRIVEWAY TO BE 5" MINIMUM THICKNESS.

OTHER SIDEWALK PANELS TO BE 4" MIN. THICKNESS.

ALL CONCRETE TO BE 3000 P.S.I. MIX WITH NATURAL COLOR AND BROOM FINISH.

IF SITE CONDITIONS PROHIBIT THE USE OF THESE STANDARDS, AN ALTERNATIVE MAY BE SUBMITTED FOR APPROVAL TO THE ENGINEERING DEPT.



## CITY OF MOBILE, ALABAMA ENGINEERING DEPARTMENT

NEUTRAL GROUND, C & G, SIDEWALK DETAILS FOR ASPHALT ROADWAY W/ C & G

**STANDARD DRAWING 4** 

SHEET 1 OF 1

05-05-15